



ANNEXURE

18

19

Fire and Emergency Services

Vadodara Mahanagar Seva Sadan
Dandia Bazar, Vadodara. 390209
Phone : 2413635, 2413754

TO WHOM SOEVER IT MAY CONCERN

This is to certify that Urmi School & Hostel, (Sama) Amit Nagar, Sama Savli Road, Nr. Flyover Bridge, Vadodara have installed following types of portable Fire Extinguisher at their School premises for Fire and Safety purpose.

- | | |
|--|---------|
| 1. 5 Kg. DCP Type Fire Extinguishers | 02 Nos. |
| 2. 9 Ltrs. Water CO2 Type Fire Extinguishers | 01 Nos. |
| 3. 2 Kg CO2 ABC Type Fire Extinguishers | 06 Nos. |
| 4. 5 Kg CO2 ABC Type Fire Extinguishers | 05 Nos. |

We have given advice to the PRO of the school to train the staff and the watchman and also children to how to operate and where to operate the fire extinguishers in case of small fire and keep always all fire extinguishers in working condition.

We are also enclosing herewith some important suggestions for fire and safety kindly follows it strictly.

This certificate is issued on written request from the school for one year period from 7/05/2018 to 06/05/2019.

Encl: Fire & Safety suggestions for Educational School.



Chief Officer (Fire)
Mahanagar Seva Sadan,
Vadodara.

Copy to :-
Urmi School & Hostel (Sama)
Amit Nagar Sama Savli Road,
Nr. Fly Over Bridge,
Vadodara.

Urmi School Manager

Principal
URMI SCHOOL

Principal
URMI SCHOOL



Manager
URMI SCHOOL



Fire and Emergency Services

Vadodara Mahanagar Seva Sadan
Dandia Bazar, Vadodara. 390209
Phone : 2413635, 2413754

Dt. 07/05/2018

TO WHOM SOEVER IT MAY CONCERN

- 1) At least two doors should be in each class room.
- 2) Canteen should be kept on ground floor or any other separate place. It should have Exit passage. Exhaust fan, and 5 kg. DCP Fire Extinguishers in adequate quantity.
- 3) If LPG Cylinder is used in the canteen, the canteen room must have adequate ventilation to Prevent Gas cylinders should be kept outside the room at safe distance.
- 4) When building is not in use probably in the night and after school hours, close the electric Supply switch off the main switch.
- 5) Each room must be connected by speaker of P.A. System.
- 6) Fire Bell or Siren or Alarm System should be kept in such a way that all student of each room of Each floor can hear it properly.
- 7) Training should be given to all staff on duty about the use of all types of Fire Extinguishers regarding Fire and Safety.
- 8) Student also should be given primary knowledge of Fire and Safety.
- 9) Telephone number of Fire Brigade Central Control room No. 101 and nearby Fire Station should be written in the main Office in bold letters in such a way that everybody can look it.
- 10) Class wise record should be maintained of all student's Name, their parent's names, Home address and their Telephone numbers to contact in the emergency.
- 11) 5 Mtrs. Height and 6 Mtrs. Wide approach road to the Main gate or entrance of building should Kept open for the Fire Brigade vehicle for Fast to do the Fire Fighting and rescue operation in emergency.
- 12) A First Aid Box should be kept in the Building at the common place.
- 13) Passage way to the stair case should be of at least 5 Ft. width.
- 14) Wood or any other inflammable article should not be used in partition, Flooring, Ceiling and staircase etc.
- 15) Parents of each student should be given the Telephone Number of the Principal strictly.



Chief Officer (Fire)
Mahanagar Seva Sadan,
Vadodara.

Copy to :-
Urmi School & Hostel (Sama)
Amit Nagar Sama Savli Road,
Nr. Fly Over Bridge,
Vadodara.

Principal
URMI SCHOOL

P.D.
Urmi School Manager

Principal
URMI SCHOOL



Manager
URMI SCHOOL